



CITY OF BIRMINGHAM FIRE DEPARTMENT

572 SOUTH ADAMS • BIRMINGHAM, MICHIGAN 48009 • 248.530.1900 FAX 248.530.1950

APPLICATION TO RECEIVE EQUIPMENT FOR BUSINESS USE IN OUTDOOR DINING

The City was awarded a grant from Oakland County to assist businesses as they provide outdoor dining during the COVID-10 pandemic.

The applicant would like to advantage of this grant by receiving the equipment listed herein. The applicant understands that if the equipment it receives in connection herewith is **not** in compliance with the terms contained herein, the application is void and the City will take back said equipment.

The applicant receives this equipment and will not violate any local, state or federal laws or orders.

To the fullest extent permitted by law, the applicant and any entity or person for whom applicant is legally liable, agrees to be responsible for any liability, defend, pay on behalf of, indemnify, and hold harmless the City of Birmingham, its elected and appointed officials, employees and volunteers and others working on their behalf against any and all claims, demands, suits, or loss, including all costs and reasonable attorney fees connected therewith, and for any damages which may be asserted, claimed or recovered against or from the City, its elected and appointed officials, employees, volunteers or others working on their behalf, by reason of personal injury, including bodily injury and death and/or property damage, including loss of use thereof, which arise out of the acts, errors or omissions of the applicant including its employees and agents, in the performance of this Agreement. Such responsibility shall not be construed as liability for damage caused by or resulting from the sole act or omission of its elected or appointed officials, employees, volunteers or others working on behalf of the City.

Received Equipment Usage Provisions

Use of Propane Tanks:

Storage

- Propane tanks whether full or empty shall be stored in an approved ventilated metal enclosure designed for propane storage and in the upright position (full or empty) at all times with the valve closed.
- Storage of propane tanks shall be protected against vehicular damage.
- Tanks shall not be stored in buildings at any time.
- Tanks shall be stored a minimum of 10 feet from exit access doors, stairways and exits in buildings with only one exit. A minimum of 5 feet from exit access doors, stairways and exits in buildings with more than one exit.
- Tanks shall be stored a minimum of 20 feet away from vehicle fueling.
- Tank storage shall be stored a minimum of 10 feet from combustible materials.

Operation

- Propane heating devices are for outdoor use only and shall not be operated in any enclosed spaces, including tents, greenhouses, igloos or any other structure.
- Proper ventilation shall be maintained at all times.
- Propane heating devices shall be operated in accordance with manufacturer's instructions.
- Proper clearances around heating devices shall be maintained at all times.
- Heating and open flame devices shall be properly located to minimize exposure to ignition sources.
- Heating devices shall not impede egress pathways.
- At all times, supply lines shall be protected against physical or mechanical damage.

General Safety

- "No Smoking" signs shall be posted in areas where propane is used or stored.
- Smoking and other sources of ignition are not permitted within 25 feet of propane tanks whether in use or stored.
- Tank valves shall be secured against tampering and unauthorized use at all times.

Note

- For propane tanks larger than 20 pounds, an application for a Fire Prevention License shall be obtained from the City Clerk's office Located at City Hall. (Site plan and field inspection with tank location shown is required).
- **Citations will be issued for any violations of improper storage and operation of propane.**

Applicant Name: _____

Organization Name: _____

Address: _____

Type of Equipment: _____

Date Equipment is Received: _____

Received by: Signature _____ Printed Name: _____

Birmingham Staff _____